

Our Ref: HL/M120297
Test Report: MAT/LAB 441E

17th September 2012

Kimplas Piping Systems Ltd.
B-29 Midc Ambad,
Nasik – 422 010,
India

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYVINYLCHLORIDE (PVC, PVC-U AND CPVC) – COMPONENTS

5300

Kimplas Trustlene fitting. Black coloured, injection moulded PVC fitting. For use with water up to 23°C.

APPROVAL NUMBER: 1208519


APPROVAL HOLDER: KIMPLAS PIPING SYSTEMS LTD.

The Scheme reserves the right to review approval. This approval is valid between August 2012 and August 2017.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme