

Approval Number: 1707519  
Test Report: MAT/LAB 434M



21<sup>st</sup> June 2017

Kimplas Piping Systems Ltd.  
B-20 Midc Ambad,  
Nasik - 422 010,  
India

Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)  
CONSECUTIVE MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYETHYLENE - COMPONENTS.**

**5240**

'Trustlene PE-80 Fittings'. Black coloured, injection moulded, PE80 electrofusion and spigot fittings. For use with water up to 23°C.

**APPROVAL NUMBER: 1707519**  
**APPROVAL HOLDER: KIMPLAS PIPING SYSTEMS LTD.**

This is a re-approval of 1206560 which is valid between June 2012 and June 2017.

The Scheme reserves the right to review approval.  
Approval 1707519 is valid between July 2017 and July 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme